

**PROFORMA**  
**RECOMMENDATION FOR BEYOND ECONOMIC REPAIR (RBER)**  
**BIOMEDICAL EQUIPMENT MAINTENANCE PROGRAM (BEMP)**

Name of Hospital: THQH MANNARKKAD	Name of District: PALAKKAD
Name of Equipment: UPS	Equipment ID & Barcode:# 133490 - 0921812
Make: SOCOMEC	Model: 17YET30B
Serial Number: 3117800158	Warranty details: No Warranty
Date of purchase/ Year of manufacture/ Installation Date: Ticket master Installation date=01/01/2018	Present status of the equipment: Fully damage
Date of breakdown:05/09/2024	*AMC/ CAMC Period agreed at the time of purchase:No AMC/CAMC
Date of registration of complaint through email/ Toll free): Toll Free	

**Action taken:** Checked the UPS found not switching on. Problem with Driver cum charger PCB and control card damaged. Need to replace these spare for further checking.

Recommendations for repair (required service details) No recommendations

Cost of spares (specify parts and cost):  
 Driver cum charger PCB and control card = 14000/-  
 GST 18% = 2520/-  
**TOTAL = 16520/-**

# Percentage value of the cost of spares with respect to Cost of Purchase/ Asset Value:86.94%	Asset Value:19000/-
---	---------------------

Abstract of Service Report provided by the OEM/ Authorized Service Provider/ CYRIX (Attached or Not)  
 Service report and Quotation attached

**Reasons for recommending the equipment as BER:** Checked the UPS found not switching on. Problem with Driver cum charger PCB and control card damaged. Need to replace these spare for further checking. Ticket master installation date is 01/01/2018 and aged upto 6 years 8 months.Repairing cost is 86.94% both criteria for RBER met. As per tender clause 5.3.14.1 we recommending for condemnation.


Name & Signature of CYRIX Authority with date  
 AKHILESH P  
 24/09/24

Remarks of Junior Consultant (Biomedical) NHM:  
 Installation date of ups is 01/01/2018 and aged up to 6 years. Repairing cost is 86.94% of asset value. Both criteria of RBER met. Hence recommended for BER.

Recommended for BER (Yes/ No): <b>Yes</b>	Consultant (Biomedical Engg) NHM (Aayyakeralam), Palakkad Signature of JC BME(NHM) 25/09/24
Date: <b>25/09/24</b>	

Date: **28/9/24** Signature of Superintendent / Medical Officer (i/c)

\*Not mandatory. Based on the period of life and value as per the BER guidelines. Attach Photograph



**താലൂക്ക് ആസ്ഥാന ആശുപത്രി**  
**മണ്ണാർക്കാട്**





# BIOMEDICAL EQUIPMENT MAINTENANCE PROGRAMME UNDER NATIONAL HEALTH MISSION



**SERVICE PROVIDER**  
Tender No. WO-37/2021-2022/698

No : 1007562

## CYRIX<sup>®</sup>

HEALTH CARE PVT LTD

ISO 13485 : 2012 & ISO 9001-2008 CERTIFIED COMPANY | AERB Approved Service Agency

**Service Report**

30/64 1 B, Petta Junction, Poonithura, Kochi- 682 038, Kerala  
Ph : 98472 99500 Website : www.cyrix.com | Email : bemp.kl@cyrix.in

<p>Health Facility: <u>THQH MANNARKAD</u></p> <p>Address: <u>MANNARKAD</u> <u>PALAKKAD</u></p> <p>Ph: <u>9605513367</u></p>	<p>Call Registration Date: <u>5/9/2024</u></p> <p>Caller ID: <u>133490</u></p> <p>Date of Visit: <u>6/9/2024</u></p> <p>Asset No: <u>0921812</u></p> <p>EQPT Name: <u>UPS</u></p> <p>Manufacture <u>SOCOMECC</u> Model: <u>17YETW030B</u></p> <p>S. No. <u>3117800158</u> Dept. <u>XRAY</u></p>
---	---

Service Classification : Breakdown call  PMS  Calibration  Cust. Training

Problem Identified : Machine not working

Action Taken : checked the ups found not switching on. problem with driver gum charger pcb and control card damaged. Need to replace these spare for further checking.

Completed  Date: 6/9/2024 Time : 11:00 Am Spare Required

Spare Replaced  Requested

Description	Qty.	Part Number	PR Number
1.			
2.			
3.			

Cyrix Engineer	Date	Start Time	End Time
<u>SREETHI.C</u>	<u>6/9/2024</u>	<u>9:30 Am</u>	<u>11:00 Am</u>

Customer Remark  Completed  Pending

Service Engineer Name : SREETHI.C

Signature: [Signature]

Date: 6/9/2024

Contact Number: 9072522058

Customer Name : pushp...


Signature: [Signature]

Date: 6/9/2024

Contact Number: 9605513367

Designation : Radiographer

Hospital Seal



Handwritten notes and signatures in Malayalam and English.



**S P D POWER LABZ Pvt Ltd.**  
Securing Power Distribution

GSTIN/UIN: 32ABJCS4412K1ZD

**S P D Power Labz Pvt Ltd**  
Ground Floor,66/1618,Peyoli Road,  
Kacheripady,Ernakulam,Pin-682018.

24 SEPT 2024
1 WEEK
SPD/UPS/SER/ 240924/3

Customer:  

**CYRIX HEALTH CARE**

**SUB:SERVICE CHARGE FOR THALUK HOSPITAL,MANNARKAD,SOCOMEK 3 KVA UPS**

SL.NO.	DESCRIPTION	QTY	UNIT PRICE	TOTAL
1	SOCOMEK 3 KVA UPS,0921812 Ups servicing, Battery checking. Replacement of Driver cum charger PCB and Control card	1	14000.00	14000.00

Subtotal	INR	<b>14000.00</b>
Discount	N/A	
GST RATE	18%	
GST		<b>2520</b>
<b>Total</b>	<b>INR</b>	<b>16520.00</b>

Please confirm your acceptance of this quote by signing this document

Signature

Name

Date

**Thank you for your business!**

**Should you have any enquiries concerning this quote, please contact**

**[SPD POWER LABZ - COMPLETE SOLUTION FOR UPS & BATTERIES](#)**

Tel:0484-4014004

Email: [service.ups@spdpowerlabz.in](mailto:service.ups@spdpowerlabz.in)

Mobile:8129998245

GSTIN/UIN: 32ABJCS4412K1ZD

**Online U P S , Offline U P S , Servo Stabilizer , Batteries - Sales & Service**



---

**REQUIRED SERVICE PROPOSAL 0921812 # 133490 UPS @ THQH MANNARKKAD , PALAKKAD**

2 messages

---

**Akhilesh P** <akhileshcyrix@gmail.com>

Tue, 24 Sept, 2024 at 11:57 am

To: service.ups@spdpowerlabz.in

Cc: DM Sarang-KLBEMP <dm1.klbemp@cyrix.in>, Blesson Jose <Zm2.klbemp@cyrix.in>

Dear sir,

Please share the price and service availability of UPS @ THQH MANNARKKAD , PALAKKAD  
Details are furnished below

Hospital Name : THQH MANNARKKAD ,PALAKKAD

Department : X RAY DEPARTMENT

Equipment Name : 3KV UPS

Make : SOCOMEC

Model : 3kv UPS

SN : 3117800158

Thanks & Regards

AKHILESH P  
DISTRICT INCHARGE - PALAKKAD  
Bemp-Kerala  
Mobile : +91 7593847154  
Email : [akhileshcyrix@gmail.com](mailto:akhileshcyrix@gmail.com)

CYRIX HEALTHCARE (P) LTD  
30/641B, Petta, Punithura  
Ernakulam- 682038  
[www.cyrixhealthcare.com](http://www.cyrixhealthcare.com)

---

**Service.UPS** <service.ups@spdpowerlabz.in>

Tue, 24 Sept, 2024 at 12:33 pm

To: Akhilesh P <akhileshcyrix@gmail.com>

Cc: DM Sarang-KLBEMP <dm1.klbemp@cyrix.in>, Blesson Jose <Zm2.klbemp@cyrix.in>, Deepak K N <deepakkn@spdpowerlabz.in>, praveenk@spdpowerlabz.in, Shinoj Mohan <shinoj@spdpowerlabz.in>

Dear Akhilesh,

Please find the attached quotation for your reference.

[Quoted text hidden]

--

**(Neona UPS changed to SPD Power Labz Pvt Ltd)**

**COMPLETE SOLUTION FOR UPS & BATTERIES**

**(UPS AMC & SERVICE PROVIDER)**

*With Thanks & Regards*

*Praveen K*



**S P D POWER LABZ Pvt Ltd.**  
Securing Power Distribution

S P D Power Labz Pvt Ltd  
Ground Floor 66/16/18, Peyoli Road  
Kacheripady, Ernakulam 682018  
Phone: 0484 - 4014004  
Mobile : 8129998245  
Email: [praveenk@spdpowerlabz.in](mailto:praveenk@spdpowerlabz.in)  
Website: [www.spdpowerlabz.in](http://www.spdpowerlabz.in)



# STOCK REGISTER

71

Name of Article COMPUTED RADIOGRAPHY SYSTEM  
 വസ്തു ന്റെ നാമം

Date തിരി	PARTICULARS വിവരണം	Bill No. ബില്ല നമ്പർ	Receipt പ്രാപ്തി	Issue ദേശ	Balance ശേഷി	Remarks ട്രിപ്പി
1.1.2019	Fuji Computed Radiography System with Accessories [Receive from KMSCL]  Including CaseKas Films 17x14 - 1 17x14 - 1 (100 Nos) 14x14 - 1 12x10 - 2 12x10 - 2 (300 Nos) 10x8 - 1 10x8 - 4 (600 Nos)		1	1	1	RS 11105192 KMSCL Supply  Jali
10/1/19	Issued for installation and installed on 10/1/19.					Jali
7-1-2019.	1. Fuji imaging plate (IP-65T35.4x35.4cm/E) 2. IP Cassette - Ip Cass - CC BW PB 35.4x35.4cm/E 3. DELL 19" MONITOR (The above 3 items received from store)		1 1 1		1 1 1	Jali
10/1/19	Issued for installation and installed on 10/1/19					Jali



താലൂക്ക് ആസ്ഥാന ആശുപത്രി  
 മണ്ണാർകട





**NEONA** **SOCOMEC**  
Innovative Power Solutions


FOR SERVICE THIS UNIT PLEASE CALL  
**8129998422, 8129998245, 0484 - 4014004**  
 service\_ups@neonainnovation.com

MODEL	ITYE 70030B	SERIAL No.	3117800158
CAPACITY	3KVA	DC VOLTAGE	72VDC
COMMISSIONING DATE			
BATTERY MAKE	CSB	AH7AH QTY	6NOS

41/1854, Veekshanam Road, Near Kacheripady, Cochin, Kerala, INDIA. Pin: 6820  
 www.neonapowersolutions.com

THIRUVANANTHAPURAM | KOCHI | KOZHIKODE

**CYRIX BIOMEDICAL EQUIPMENT MAINTENANCE PROGRAMME (BEMP)**  
 TOLL FREE NO: 1800 - 425-7669  
 BAR CODE - (8004-890615225) 0921812



Handwritten signature in green ink.

സുപ്രണ്ട്  
 താലൂക്ക് ആസ്ഥാന ആശുപത്രി  
 മണ്ണൂർക്കാട്